

**RFQ Request for Clarification Response #5:**

**#1)**

**Q) Will the required security station in the foyer of the building or any agency require a package X-ray machine or metal detector?**

**A) No, the agencies do not require an X-ray machine or Metal Detector.**

**#2)**

**Q) How much of the Communication System is the State going to provide?**

**A) State to provide servers, computers, phone handsets and internal office cabling. Developer shall provide the following:**

- 1) 1 Gb/s fiber to bottom floor riser room with power.**
- 2) All internal cabling to provide a minimum of 25 mb/s data to each desk for a minimum of 450 people.**
- 3) All phone lines for a minimum of 450 people.**
- 4) Riser fiber and cabling locations per floor with power. Must be able to separate all functions per floor and be located in a secure location.**
- 5) Secure locations for telephone switching and distribution, with power. It will include all necessary functions but switching, including main frame functions.**
- 6) All infrastructure shall meet EITS specifications.**